## FM Approvals **CERTIFICATE OF CONFORMITY** Member of the FM Global Grou 1. HAZARDOUS LOCATION ELECTRICAL PER CANADIAN REQUIREMENTS 2. **Certificate No:** FM17CA0033X 3. Equipment: FEP63 \_ ProcessMaster, and (Type Reference and Name) FEH63\_ HygienicMaster Electromagnetic Flowmeters, and FET63\_Transmitters Name of Listing Company: ABB Automation Products GmbH 4. Dransfelder Straße 2, Address of Listing Company: 5. D-37079 Göttingen, Germany The examination and test results are recorded in confidential report number: 6. 3059596 dated 22<sup>nd</sup> May 2018 7. FM Approvals LLC, certifies that the equipment described has been found to comply with the following Approval standards and other documents: CSA C22.2 No. 25: 2017, CSA C22.2 No. 30: 1986 (R2016), CSA C22.2 No. 94.1: 2015, CSA C22.2 No. 94.2: 2015, CSA C22.2 No. 213: 2017, CAN/CSA-C22.2 No. 60079-0: 2015, CAN/CSA-C22.2 No. 60079-1: 2016, CAN/CSA-C22.2 No. 60079-7: 2016, CAN/CSA-C22.2 No. 60079-11: 2014, CAN/CSA-C22.2 No. 60079-18: 2016, CAN/CSA-C22.2 No. 60079-31: 2015, CAN/CSA C22.2 No. 60529: 2016, CAN/CSA C22.2 No. 61010-1: 2004, and ANSI/ISA 12.27.01: 2011 If the sign 'X' is placed after the certificate number, it indicates that the equipment is subject to specific 8. conditions of use specified in the schedule to this certificate. 9. This certificate relates to the design, examination and testing of the products specified herein. The FM Approvals surveillance audit program has further determined that the manufacturing processes and quality control procedures in place are satisfactory to manufacture the product as examined, tested and Approved. Certificate issued by: anguerdi 22 May 2018 J. É. Marquedant Date VP, Manager, Electrical Systems To verify the availability of the Approved product, please refer to www.approvalguide.com THIS CERTIFICATE MAY ONLY BE REPRODUCED IN ITS ENTIRETY AND WITHOUT CHANGE





#### 10. Equipment Ratings:

#### FE\*631F1D (6 and 8) - Integral transmitter & sensor

Explosionproof for Class I, Division 1, Groups B, C and D T6...T1; Dust-ignitionproof for Class II, Division 1, Groups E, F and G T6...T1; Class III, Division 1 T6...T3B, Flameproof/increased safety/encapsulated with intrinsically safe outputs for Class I, Zone 1, Ex db eb mb [ia Ga] IIB+H2 T6...T1 Gb, protection by enclosure with intrinsically safe outputs for Zone 21 Ex tb [ia Da] IIIC T80°C...T165°C Db, hazardous locations, indoors and outdoors (Type 4X, IP65/67) with an ambient temperature rating of -40°C to +60°C.

#### FE\*632F1A (1 and 2) – Remote sensor

#### FE\*632F1U (1 and 2) - Remote sensor

Explosionproof for Class I, Division 1, Groups B, C and D T6...T1; Dust-ignitionproof for Class II, Division 1, Groups E, F and G T6...T1; Class III, Division 1 T6...T3B, Flameproof/increased safety/encapsulated for Class I, Zone 1, Ex db eb mb IIB+H2 T6...T1 Gb, protection by enclosure/intrinsic safety?? for Zone 21 Ex tb IIIC T80°C...T165°C Db hazardous locations, indoors and outdoors (Type 4X, IP65/67) with an ambient temperature rating of -40°C to +60°C.

#### FET631F1W (5 and 7) – Transmitter only

Explosionproof for Class I, Division 1, Groups B, C and D; Dust-ignitionproof for Class II, Division 1, Groups E, F and G; Class III, Division 1, Flameproof/increased safety/encapsulated with intrinsically safe outputs for Class I, Zone 1, Ex db eb mb IIB +  $H_2$  T6 Gb, protection by enclosure for Zone 21 Ex tb IIIC T80°C Db hazardous locations, indoors and outdoors (Type 4X, IP65/67) with an ambient temperature rating of -40°C to +60°C.

#### FE\*631F2 – Integral transmitter & sensor

#### FEP632F2 – Remote sensor

#### FEH632F2 – Remote sensor

Nonincendive for Class I Division 2, Groups A, B, C and D T6...T1, Nonincendive for Class II, Division 2, Groups E, F and G, T6...T3B, Class III, Division 1, T6...T3B, Increased safety for Class I, Zone 2 Ex ec IIC T6...T1 Gc, protection by enclosure for Zone 21 Ex tb IIIC T80°C...T165°C Db hazardous locations, indoors and outdoors (Type 4X, IP65/67) with an ambient temperature rating of -40°C to +60°C.

#### FET631F2– Remote transmitter

Nonincendive for Class I Division 2, Groups A, B, C and D, Nonincendive for Class II, Division 2, Groups E, F and G, Class III, Division 1, Increased safety for Class I, Zone 2 Ex ec IIC T6 Gc, protection by enclosure for Zone 21 Ex tb IIIC T80°C...T165°C Db hazardous locations, indoors and outdoors (Type 4X, IP65/67) with an ambient temperature rating of -40°C to +60°C.

11. The marking of the equipment shall include:

#### FE\*631F1D (6 and 8)

Class I Division 1, Groups B, C, D; T6...T1 Ta = -40°C to +60°C; Type 4X, IP65/67

#### THIS CERTIFICATE MAY ONLY BE REPRODUCED IN ITS ENTIRETY AND WITHOUT CHANGE

# **SCHEDULE**



## Canadian Certificate Of Conformity No: FM17CA0033X

Class II, Division 1, Groups E, F, G, Class III, Division 1; T6...T3B Ta =  $-40^{\circ}$ C to  $+60^{\circ}$ C; Type 4X, IP65/67 Class I, Zone 1, Ex db eb mb [ia Ga] IIB+H2 T6...T1 Gb Ta =  $-40^{\circ}$ C to  $+60^{\circ}$ C; Type 4X, IP65/67 Zone 21, Ex tb [ia Da] IIIC T80°C...T165°C Db Ta =  $-40^{\circ}$ C to  $+60^{\circ}$ C; Type 4X, IP65/67

## FE\*632F1A (1 and 2) FE\*632F1U (1 and 2)

Class I Division 1, Groups B, C, D; T6...T1 Ta = -40°C to +60°C; Type 4X, IP65/67 Type 4X, IP65/67/68 Class II, Division 1, Groups E, F, G, Class III, Division 1; T6...T3B Ta = -40°C to +60°C; Type 4X, IP65/67/68 Zone 1, Ex db eb mb IIB+H2 T6...T1 Gb Ta = -40°C to +60°C; Type 4X, IP65/67/68 Zone 21, Ex tb ia IIIC T80°C...T165°C Db Ta = -40°C to +60°C; Type 4X, IP65/67/68

#### FET631F1W (5 and 7)

Class I Division 1, Groups B, C, D; T6 Ta =  $-40^{\circ}$ C to  $+60^{\circ}$ C; Type 4X, IP65/67 Class II, Division 1, Groups E, F, G, Class III, Division 1; T6 Ta =  $-40^{\circ}$ C to  $+60^{\circ}$ C; Type 4X, IP65/67 Zone 1, Ex db [ia Ga] IIB + H<sub>2</sub> T6 Gb Ta =  $-40^{\circ}$ C to  $+60^{\circ}$ C; Type 4X, IP65/67 Zone 21, Ex tb [ia Da] IIIC T80°C Db Ta =  $-40^{\circ}$ C to  $+60^{\circ}$ C; Type 4X, IP65/67

#### FE\*631F2

## FEP632F2

#### FEH632F2

Class I Division 2, Groups A, B, C, D; T6...T1 Ta = -40°C to +60°C; Type 4X, IP65/67/68 (sensor only) Class II, Division 2, Groups E, F, G, Class III, Division 1; T6...T3B Ta = -40°C to +60°C; Type 4X, IP65/67/68 (sensor only)

Zone 2, Ex ec IIC T6...T1 Gc Ta =  $-40^{\circ}$ C to  $+60^{\circ}$ C; Type 4X, IP65/67/68 (sensor only) Zone 21, Ex tb IIIC T80°C...T165°C Db Type 4X, IP65/67/68 (sensor only)

#### **FET631F2**

Class I Division 2, Groups A, B, C, D; T6 Ta = -40°C to +60°C; Type 4X, IP65/67 Class II, Division 2, Groups E, F, G, Class III, Division 1; T6 Ta = -40°C to +60°C; Type 4X, IP65/67 Zone 2, Ex ec IIC T6 Gc Ta = -40°C to +60°C; Type 4X, IP65/67 Zone 21, Ex tb IIIC T80°C Db Type 4X, IP65/67

#### 12. Description of Equipment:

#### THIS CERTIFICATE MAY ONLY BE REPRODUCED IN ITS ENTIRETY AND WITHOUT CHANGE





**General** - The FEP6\_ \_ ProcessMaster, and FEH6\_ \_ HygienicMaster are series of electromagnetic flowmeters. The electronics enclosure is a cylindrical enclosure identified as a Type 3 or a single compartment a rectangular housing identified as a Type 4. The ambient temperature range for the transmitters and sensors is either -20°C to +60°C or - 40°C to +60°C depending on the options chosen.

The FEP6\_ \_ ProcessMaster, and FEH6\_ \_ HygienicMaster are both available as integral and remote designs. A high process temperature version is available and uses different length stand-offs between the Primary and the electronics or remote connection facilities.

The sensor is available in two different versions: Process Sensor and Hygienic Sensor. The Process Sensor is available in meter size DN3 to DN2000, the Hygienic Sensor is available in meter size DN3 to DN100. The medium temperature range for the Hygienic Sensor and the medium temperature range for the Process Sensor identified as Design Level A are -40 °C to 130 °C for the normal temperature version and -40 °C to +180 °C for the high temperature version. The medium temperature range for sensors identified as Design Level B is -40 °C to 100 °C.

Enclosure rating IP65, IP67, or IP68 depending on the option selected.

#### Operation Temperature Ranges:

The ambient operating temperature range of the FE\*6 is -40°C to 60°C. Process temperature range is -40°C to 180°C. See ABB Instruction manual for details on the relationship between ambient temperature, process temperature and temperature class.

Electrical data: The FE\*6 has the following supply parameters;

Power Supply (Terminals L and N)  $U_{DC} = 16.8 \text{ to } 30 \text{ V}$  $U_{AC} = 100 \text{ V} (-15\%) \text{ to } 240 \text{ V} (+10\%)$ 

Power supply (=  $U_{LOW}$ );  $P_{MAX} = \le 20$  W; C, Ripple < 5 % Power supply (=  $U_{HIGH}$ ); S  $\le 20$  W


See ABB Instruction Manual for the parameters for the Current Output, Digital Output, and Digital Input connections.

#### FEH631F2fghijklmnopqrA-t.u.v – Hygienic Integral FM17CA0033X


NI/ I / 2 / ABCD / T6...T1 Ta = +60°C; Type 4X, IP65/67 NI / II / 2 / EFG / T6...T3B Ta = +60°C; Type 4X, IP65/67 DIP / III / 1 / T6...T3B Ta = +60°C; Type 4X, IP65/67 2 / Ex ec / IIC / T6...T1 Gc Ta = +60°C; Type 4X, IP65/67 21 / Ex tb / IIIC / T80°C...T165°C Db Ta = +60°C; Type 4X, IP65/67 Single Seal

- f = Housing Type/Housing Material/ Cable entry: S1, S2, D1, D2, D3, D4, D6, or D8
- g = Meter Size: 4-digit code not relevant for safety
- h = Process Connection Type: 2-digit code not relevant for safety
- i = Liner material: T1 or P1
- j = Process connection material: Single digit not relevant for safety
- k = Electrode design: 1, or 5
- I = Measuring electrode material: Single digit code not relevant for safety
- m = Grounding electrode/Full pipe detection: 0 or 2


#### THIS CERTIFICATE MAY ONLY BE REPRODUCED IN ITS ENTIRETY AND WITHOUT CHANGE




T: +1 (1) 781 762 4300 F: +1 (1) 781 762 9375 E-mail: information@fmapprovals.com www.fmapprovals.com




T: +1 (1) 781 762 4300 F: +1 (1) 781 762 9375 E-mail: information@fmapprovals.com www.fmapprovals.com





FM Approvals LLC. 1151 Boston-Providence Turnpike, Norwood, MA 02062 USA T: +1 (1) 781 762 4300 F: +1 (1) 781 762 9375 E-mail: <u>information@fmapprovals.com</u> <u>www.fmapprovals.com</u>



T: +1 (1) 781 762 4300 F: +1 (1) 781 762 9375 E-mail: information@fmapprovals.com www.fmapprovals.com





#### Single Seal

- Housing Type/Housing Material/ Cable entry: A1, A2, U1, or U2 f =
- Meter Size: 4-digit code not relevant for safety g =
- Process Connection Type: 2-digit code not relevant for safety h =
- Liner material: R2, R3, R4, E1, T1, T3, T2, P1, C1, E2 or P2 i =
- Process connection material: Single digit not relevant for safety j =
- Electrode design: 1, or 5 k =
- Measuring electrode material: Single digit code not relevant for safety I = 1
- Grounding electrode/Full pipe detection: 0, 1, 2 or 3 m =
- Grounding accessories: A, B, C, D or E n =
- Protection class transmitter/protection class sensor: 70, 76, 77 or 91 0 =
- Power supply: Y or W p =

Additional Codes

- Option card 1: DR0 t =
- Option card 2: DR0 u =
- Temperature range of installation/Ambient temperature range: TK1, TK4, TKH or TKK v =
- Sensor housing material: SMA or SMS w =

#### FET632F1fopqr - t.u.v - Remote transmitter FM17CA0033X

XP-IS / I / 1 / BCD / T6 Ta = +60°C; Type 4X, IP65/67 DIP / II / 1 / EFG / T6 Ta = +60°C; Type 4X, IP65/67 III / 1 / T6 Ta = +60°C; Type 4X, IP65/67

1 / Ex db [ia Ga] / IIB + H2 / T6 Gb/Ga Ta = +60°C; Type 4X, IP65/67

- 21 / Ex tb [ia Da] / IIIC / T80°C Db/Da Ta = +60°C; Type 4X, IP65/67
- f = Housing Type/Housing Material/ Cable entry: W5 or W7
- Protection class transmitter/protection class sensor: 70 or 91 0 =
- Power supply: A, D, C or E p =
- Display: 1 or 2 q =
- Outputs: G0, G1, G2, G3 or Y0 r =

Additional Codes

- Option card 1: DR0, DRN, DRG, DRT or DRA t =
- Option card 2: DR0, DSA, DSN or DSG u =
- Temperature range of installation/Ambient temperature range: TK1, TK4, TKH or TKK V =

#### Schedule of Limitations: 13.

1. The ABB Instruction Manual for the ProcessMaster and HygenicMaster details the permitted Temperature Classification and Ambient Temperature ratings as influenced by the Process Medium temperature.

The painted surface of the ProcessMaster and HygenicMaster may store electrostatic charge 2. and become a source of ignition in applications with a low relative humidity <~30% relative humidity where the painted surface is relatively free of surface contamination such as dirt, dust, or oil. Guidance on protection against the risk of ignition due to electrostatic discharge can be found in IEC TR60079-32-2 Cleaning of the painted surface should only be done with a damp cloth.

#### THIS CERTIFICATE MAY ONLY BE REPRODUCED IN ITS ENTIRETY AND WITHOUT CHANGE





3. Contact the manufacturer for specific flamepath joint details during repair of flameproof Ex d apparatus.

For Integral and Remote versions FE\*63\*F1 Zone 21 having exposed electrodes in the 4. process shall be used in a non-flammable liquid process only.

For installations in flammable dust, the cable entries shall be fitted with an appropriate cable entry 5. device meeting the requirements of IP6x fitted with a gasket or seal between the cable entry device and the wall of the enclosure.

#### 14. Test and Assessment Procedure and Conditions:

This Certificate has been issued in accordance with FM Approvals Canadian Certification Scheme.

#### 15. Schedule Drawings

A copy of the technical documentation has been kept by FM Approvals.

#### 16. Certificate History

Details of the supplements to this certificate are described below:

$\langle \langle \rangle$								
Da	ate	Description						
22	and May 2018	Original Issue.		V	U	U	U	

Approvals

## THIS CERTIFICATE MAY ONLY BE REPRODUCED IN ITS ENTIRETY AND WITHOUT CHANGE

## FM Approvals **CERTIFICATE OF CONFORMITY** Member of the FM Global Grou 1. HAZARDOUS LOCATION ELECTRICAL PER CANADIAN REQUIREMENTS 2. **Certificate No:** FM17CA0033X 3. Equipment: FEP63 ProcessMaster, and (Type Reference and Name) FEH63 HygienicMaster Electromagnetic Flowmeters, and FET63 Transmitters Name of Listing Company: ABB Automation Products GmbH 4. Dransfelder Straße 2, 5. Address of Listing Company: D-37079 Göttingen. Germany The examination and test results are recorded in confidential report number: 6. 3059596 dated 22<sup>nd</sup> May 2018 7. FM Approvals LLC, certifies that the equipment described has been found to comply with the following Approval standards and other documents: CSA C22.2 No. 25: 2017, CSA C22.2 No. 30: 1986 (R2016), CSA C22.2 No. 94.1: 2015, CSA C22.2 No. 94.2: 2015, CSA C22.2 No. 213: 2017, CAN/CSA-C22.2 No. 60079-0: 2015, CAN/CSA-C22.2 No. 60079-1: 2016, CAN/CSA-C22.2 No. 60079-7: 2016, CAN/CSA-C22.2 No. 60079-11: 2014, CAN/CSA-C22.2 No. 60079-18: 2016, CAN/CSA-C22.2 No. 60079-31: 2015, CAN/CSA C22.2 No. 60529: 2016, CAN/CSA C22.2 No. 61010-1: 2004, and ANSI/ISA 12.27.01: 2011 If the sign 'X' is placed after the certificate number, it indicates that the equipment is subject to specific 8. conditions of use specified in the schedule to this certificate. This certificate relates to the design, examination and testing of the products specified herein. The FM 9. Approvals surveillance audit program has further determined that the manufacturing processes and quality control procedures in place are satisfactory to manufacture the product as examined, tested and Approved. Certificate issued by: Marguerdi 6 July 2018 J/E. Marguedant Date VP, Manager, Electrical Systems

To verify the availability of the Approved product, please refer to  $\underline{www.approvalguide.com}$ 

## THIS CERTIFICATE MAY ONLY BE REPRODUCED IN ITS ENTIRETY AND WITHOUT CHANGE

FM Approvals LLC. 1151 Boston-Providence Turnpike, Norwood, MA 02062 USA T: +1 (1) 781 762 4300 F: +1 (1) 781 762 9375 E-mail: <u>information@fmapprovals.com</u> <u>www.fmapprovals.com</u>





#### 10. Equipment Ratings:

#### FE\*631F1D (6 and 8) - Integral transmitter & sensor

Explosionproof for Class I, Division 1, Groups B, C and D T6...T1; Dust-ignitionproof for Class II, Division 1, Groups E, F and G, T6...T3B; Class III, Division 1, T6...T3B, Flameproof/increased safety/encapsulated with intrinsically safe outputs for Class I, Zone 1, Ex db eb mb [ia Ga] IIB+H2 T6...T1 Gb, protection by enclosure with intrinsically safe outputs for Zone 21 Ex tb [ia Da] IIIC T80°C...T165°C Db, hazardous locations, indoors and outdoors (Type 4X, IP65/67) with an ambient temperature rating of -40°C to +60°C.

#### FE\*632F1A (1 and 2) – Remote sensor

#### FE\*632F1U (1 and 2) - Remote sensor

Explosionproof for Class I, Division 1, Groups B, C and D T6...T1; Dust-ignitionproof for Class II, Division 1, Groups E, F and G, T6...T3B; Class III, Division 1, T6...T3B, Flameproof/increased safety/encapsulated for Class I, Zone 1, Ex db eb mb IIB+H2 T6...T1 Gb, protection by enclosure/intrinsic safety for Zone 21 Ex tb IIIC T80°C...T165°C Db hazardous locations, indoors and outdoors (Type 4X, IP65/67) with an ambient temperature rating of -40°C to +60°C.

#### FET632F1W (5 and 7) - Transmitter only

Explosionproof for Class I, Division 1, Groups B, C and D; Dust-ignitionproof for Class II, Division 1, Groups E, F and G, T6; Class III, Division 1, T6; Flameproof/increased safety/encapsulated with intrinsically safe outputs for Class I, Zone 1, Ex db [ia Ga] IIB + H<sub>2</sub> T6 Gb, protection by enclosure for Zone 21 Ex tb [ia Da] IIIC T80°C Db hazardous locations, indoors and outdoors (Type 4X, IP65/67 – IP68 Sensor only) with an ambient temperature rating of -40°C to +60°C.

#### FE\*632F2 – Integral transmitter & sensor

#### FEP632F2 – Remote sensor

#### FEH632F2 – Remote sensor

Nonincendive for Class I Division 2, Groups A, B, C and D T6...T1; Nonincendive for Class II, Division 2, Groups E, F and G, T6...T3B, Class III, Division 1, T6...T3B, Increased safety for Class I, Zone 2 Ex ec IIC T6...T1 Gc, protection by enclosure for Zone 21 Ex tb IIIC T80°C...T165°C Db hazardous locations, indoors and outdoors (Type 4X, IP65/67) with an ambient temperature rating of -40°C to +60°C.

#### FET631F2– Remote transmitter

Nonincendive for Class I Division 2, Groups A, B, C and D, T6; Nonincendive for Class II, Division 2, Groups E, F and G, Class III, Division 1, Increased safety for Class I, Zone 2 Ex ec IIC T6 Gc, protection by enclosure for Zone 21 Ex tb IIIC T80°C Db hazardous locations, indoors and outdoors (Type 4X, IP65/67) with an ambient temperature rating of -40°C to +60°C.

11. The marking of the equipment shall include:

#### FE\*631F1D (6 and 8)

Class I Division 1, Groups B, C, D; T6...T1 Ta = -40°C to +60°C; Type 4X, IP65/67

#### THIS CERTIFICATE MAY ONLY BE REPRODUCED IN ITS ENTIRETY AND WITHOUT CHANGE

# **SCHEDULE**



Canadian Certificate Of Conformity No: FM17CA0033X

Class II, Division 1, Groups E, F, G, Class III, Division 1; T6...T3B Ta = -40°C to +60°C; Type 4X, IP65/67 Class I, Zone 1, Ex db eb mb [ia Ga] IIB+H2 T6...T1 Gb Ta = -40°C to +60°C; Type 4X, IP65/67 Zone 21, Ex tb [ia Da] IIIC T80°C...T165°C Db

## FE\*632F1A (1 and 2) FE\*632F1U (1 and 2)

Class I Division 1, Groups B, C, D; T6...T1 Ta = -40°C to +60°C; Type 4X, IP65/67 Type 4X, IP65/67/68 Class II, Division 1, Groups E, F, G, Class III, Division 1; T6...T3B Ta = -40°C to +60°C; Type 4X, IP65/67/68 Zone 1, Ex db eb mb IIB+H2 T6...T1 Gb Ta = -40°C to +60°C; Type 4X, IP65/67/68 Zone 21, Ex tb IIIC T80°C...T165°C Db

## FET632F1W (1 to 5 and 7)

Class I Division 1, Groups B, C, D; T6 Ta =  $-40^{\circ}$ C to  $+60^{\circ}$ C; Type 4X, IP65/67 Class II, Division 1, Groups E, F, G, Class III, Division 1; T6 Ta =  $-40^{\circ}$ C to  $+60^{\circ}$ C; Type 4X, IP65/67 Zone 1, Ex db [ia Ga] IIB + H<sub>2</sub> T6 Gb Ta =  $-40^{\circ}$ C to  $+60^{\circ}$ C; Type 4X, IP65/67 Zone 21, Ex tb [ia Da] IIIC T80°C Db

#### FE\*631F2

#### FEP632F2

## FEH632F2

Class I Division 2, Groups A, B, C, D; T6...T1 Ta = -40°C to +60°C; Type 4X, IP65/67/68 (sensor only) Class II, Division 2, Groups E, F, G, Class III, Division 1; T6...T3B Ta = -40°C to +60°C; Type 4X, IP65/67/68 (sensor only)

Zone 2, Ex ec IIC T6...T1 Gc Ta = -40°C to +60°C; Type 4X, IP65/67/68 (sensor only) Zone 21, Ex tb IIIC T80°C...T165°C Db

## FET632F2

Class I Division 2, Groups A, B, C, D; T6 Ta = -40°C to +60°C; Type 4X, IP65/67 Class II, Division 2, Groups E, F, G, Class III, Division 1; T6 Ta = -40°C to +60°C; Type 4X, IP65/67 Zone 2, Ex ec IIC T6 Gc Ta = -40°C to +60°C; Type 4X, IP65/67 Zone 21, Ex tb IIIC T80°C Db

#### 12. Description of Equipment:

## THIS CERTIFICATE MAY ONLY BE REPRODUCED IN ITS ENTIRETY AND WITHOUT CHANGE





**General** - The FEP6\_ \_ ProcessMaster, and FEH6\_ \_ HygienicMaster are series of electromagnetic flowmeters. The electronics enclosure is a cylindrical enclosure identified as a dual compartment Type 3 or a single compartment a rectangular housing identified as a Type 4. The ambient temperature range for the transmitters and sensors is either -20°C to +60°C or -40°C to +60°C depending on the options chosen.

The FEP6\_ \_ ProcessMaster, and FEH6\_ \_ HygienicMaster are both available as integral and remote designs. A high process temperature version is available and uses 40mm or 100mm stand-offs between the Primary and the electronics or remote connection facilities.

The sensor is available in two different versions: Process Sensor and Hygienic Sensor. The Process Sensor is available in meter size DN3 to DN2000, the Hygienic Sensor is available in meter size DN3 to DN100. The medium temperature range for the Hygienic Sensor and the medium temperature range for the Process Sensor identified as Design Level A are -40 °C to 130 °C for the normal temperature version and -40 °C to +180 °C for the high temperature version. The medium temperature range for sensors identified as Design Level B is -40 °C to 100 °C.

Enclosure rating IP65, IP67, or IP68 depending on the option selected.

#### Operation Temperature Ranges:

The ambient operating temperature range of the FE\*6 is -40°C to 60°C. Process temperature range is -40°C to 180°C. See ABB Instruction manual for details on the relationship between ambient temperature, process temperature and temperature class.

Electrical data: The FE\*6 has the following supply parameters;

Power Supply (Terminals L and N) U<sub>DC</sub> = 16.8 to 30 V U<sub>AC</sub> = 100 V (-15%) to 240 V (+10%)

Power supply (=  $U_{LOW}$ );  $P_{MAX} = \le 20$  W; C, Ripple < 5 % Power supply (=  $U_{HIGH}$ ); S  $\le 20$  W


See ABB Drawing Number 1KXF000061G0009 for the parameters for the Current Output, Digital Output, and Digital Input connections.

#### FEH631F2fghijklmnopqrA-t.u.v – Hygienic Integral


NI/ I / 2 / ABCD / T6...T1 Ta = +60°C; Type 4X, IP65/67 NI / II / 2 / EFG / T6...T3B Ta = +60°C; Type 4X, IP65/67 DIP / III / 1 / T6...T3B Ta = +60°C; Type 4X, IP65/67 2 / Ex ec / IIC / T6...T1 Gc Ta = +60°C; Type 4X, IP65/67 21 / Ex tb / IIIC / T80°C...T165°C Db Ta = +60°C; Type 4X, IP65/67 Single Seal

- f = Housing Type/Housing Material/ Cable entry: S1, S2, D1, D2, D3, D4, D6, or D8
- g = Meter Size: 4-digit code not relevant for safety
- h = Process Connection Type: 2-digit code not relevant for safety
- i = Liner material: T1 or P1
- j = Process connection material: Single digit not relevant for safety
- k = Electrode design: 1, or 5
- I = Measuring electrode material: Single digit code not relevant for safety
- m = Grounding electrode/Full pipe detection: 0 or 2
- n = Grounding accessories: A, B or C


#### THIS CERTIFICATE MAY ONLY BE REPRODUCED IN ITS ENTIRETY AND WITHOUT CHANGE




#### THIS CERTIFICATE MAY ONLY BE REPRODUCED IN ITS ENTIRETY AND WITHOUT CHANGE



FM Approvals LLC. 1151 Boston-Providence Turnpike, Norwood, MA 02062 USA T: +1 (1) 781 762 4300 F: +1 (1) 781 762 9375 E-mail: <u>information@fmapprovals.com</u> <u>www.fmapprovals.com</u>









- n = Grounding accessories: A, B, C, D or E
- o = Protection class transmitter/protection class sensor: 70 or 91
- p = Power supply: A, D, C, or E
- q = Display: 1 or 2
- r = Outputs: G0, G1, G2, G3, Y0

Additional Codes

- t = Option card 1: DR0, DRN, DRG, DRT or DRA
- u = Option card 2:DR0, DSA, DSN, or DSG
- v = Temperature range of installation/Ambient temperature range: TK1, TK4, TKH or TKK
- w = Sensor housing material: SMA or SMS

## FEH632F1fghijklmnop8Y0A-t.u.v – Hygienic remote sensor

XP-IPA / I / 1 / BCD / T6...T1 Ta = +60°C; Type 4X, IP65/67/68 DIP / II / 1 / EFG / T6...T3B Ta = -40°C to +60°C; Type 4X, IP65/67/68 III / 1 / T6...T3B Ta = +60°C; Type 4X, IP65/67/68 1 / Ex db eb mb / IIB+H2 / T6...T1 Gb Ta = +60°C; Type 4X, IP65/67/68 21 / Ex tb / IIIC / T80°C...T165°C Db, Type 4X, IP65/67/68 Single Seal

- f = Housing Type/Housing Material/ Cable entry: A1, A2, U1, or U2
- g = Meter Size: 4-digit code not relevant for safety
- h = Process Connection Type: 2-digit code not relevant for safety
- i = Liner material: T1 or P1
- j = Process connection material: Single digit not relevant for safety
- k = Electrode design: 1, or 5
- I = Measuring electrode material: Single digit code not relevant for safety
- m = Grounding electrode/Full pipe detection: 0 or 2
- n = Grounding accessories: A, B or C
- o = Protection class transmitter/protection class sensor: 70, 76, 77 or 91
- p = Power supply: Y or W

#### Additional Codes

- t = Option card 1: DR0
- u = Option card 2: DR0
- v = Temperature range of installation/Ambient temperature range: TK1, TK4, TKH or TKK

#### FEP632F1fghijklmnop8Y0A-t.u.v.w – Process remote sensor

XP-IPA / I / I / BCD / T6...T1 Ta = +60°C; Type 4X, IP65/67/68 DIP / II / 1 / EFG / T6...T3B Ta = -40°C to +60°C; Type 4X, IP65/67/68 III / 1 / T6...T3B Ta = +60°C; Type 4X, IP65/67/68 1 / Ex db eb mb / IIB+H2 / T6...T1 Gb Ta = +60°C; Type 4X, IP65/67/68 21 / Ex tb / IIIC / T80°C...T165°C Db, Type 4X, IP65/67/68 Single Seal

- f = Housing Type/Housing Material/ Cable entry: A1, A2, U1, or U2
- g = Meter Size: 4-digit code not relevant for safety
- h = Process Connection Type: 2-digit code not relevant for safety
- i = Liner material: R2, R3, R4, E1, T1, T3, T2, P1, C1, E2 or P2
- j = Process connection material: Single digit not relevant for safety

#### THIS CERTIFICATE MAY ONLY BE REPRODUCED IN ITS ENTIRETY AND WITHOUT CHANGE





- k = Electrode design: 1, or 5
- I = Measuring electrode material: Single digit code not relevant for safety
- m = Grounding electrode/Full pipe detection: 0, 1, 2 or 3
- n = Grounding accessories: A, B, C, D or E
- o = Protection class transmitter/protection class sensor: 70, 76, 77 or 91
- p = Power supply: Y or W

Additional Codes

- t = Option card 1: DR0
- u = Option card 2: DR0
- v = Temperature range of installation/Ambient temperature range: TK1, TK4, TKH or TKK
- w = Sensor housing material: SMA or SMS

## FET632F1fopqr - t.u.v – Remote transmitter

XP-IS / I / 1 / BCD / T6 Ta = +60°C; Type 4X, IP65/67 DIP / II / 1 / EFG / T6 Ta = +60°C; Type 4X, IP65/67 III / 1 / T6 Ta = +60°C; Type 4X, IP65/67

1 / Ex db [ia Ga] / IIB + H2 / T6 Gb Ta = +60°C; Type 4X, IP65/67

- 21 / Ex tb [ia Da] / IIIC / T80°C Db Ta = +60°C; Type 4X, IP65/67
- f = Housing Type/Housing Material/ Cable entry: W1, W2, W3, W4, W5 or W7
- o = Protection class transmitter/protection class sensor: 70 or 91
- p = Power supply: A, D, C or E
- q = Display: 1 or 2
- r = Outputs: G0, G1, G2, G3 or Y0

Additional Codes

- t = Option card 1: DR0, DRN, DRG, DRT or DRA
- u = Option card 2: DR0, DSA, DSN or DSG
- v = Temperature range of installation/Ambient temperature range: TK1, TK4, TKH or TKK

#### 13. Schedule of Limitations:

1. The ABB Instruction Manual for the ProcessMaster and HygenicMaster details the permitted Temperature Classification and Ambient Temperature ratings as influenced by the Process Medium temperature.

2. The painted surface of the ProcessMaster and HygenicMaster may store electrostatic charge and become a source of ignition in applications with a low relative humidity <~30% relative humidity where the painted surface is relatively free of surface contamination such as dirt, dust, or oil. Guidance on protection against the risk of ignition due to electrostatic discharge can be found in IEC TR60079-32-2 Cleaning of the painted surface should only be done with a damp cloth.

3. Contact the manufacturer for specific flamepath joint details during repair of flameproof Ex d apparatus.

4. For Integral and Remote versions FE\*63\*F1 Zone 21 having exposed electrodes in the process shall be used in a non-flammable liquid process only.

5. For installations in flammable dust, the cable entries shall be fitted with an appropriate cable entry device meeting the requirements of IP6x fitted with a gasket or seal between the cable entry device and the wall of the enclosure.

#### THIS CERTIFICATE MAY ONLY BE REPRODUCED IN ITS ENTIRETY AND WITHOUT CHANGE





VAIN

Canadian Certificate Of Conformity No: FM17CA0033X

## 14. Test and Assessment Procedure and Conditions:

This Certificate has been issued in accordance with FM Approvals Canadian Certification Scheme.

#### 15. Schedule Drawings

A copy of the technical documentation has been kept by FM Approvals.

#### 16. Certificate History

Details of the supplements to this certificate are described below:

Date	Description				
22 <sup>nd</sup> May 2018	Original Issue.				
6 <sup>th</sup> July 2018	Supplement 1: Report Reference: RR214851 dated 6 <sup>th</sup> July 2018. Description of the Change: Editorial corrections to the certificate.				
	FIVI AUUUVdIS				

HVI Approvals

#### THIS CERTIFICATE MAY ONLY BE REPRODUCED IN ITS ENTIRETY AND WITHOUT CHANGE

## FM Approvals **CERTIFICATE OF CONFORMITY** Member of the FM Global Grou 1. HAZARDOUS LOCATION ELECTRICAL PER CANADIAN REQUIREMENTS 2. **Certificate No:** FM17CA0033X 3. Equipment: FEP63 ProcessMaster, and (Type Reference and Name) FEH63 HygienicMaster Electromagnetic Flowmeters, and FET63 Transmitters Name of Listing Company: ABB Automation Products GmbH 4. Dransfelder Straße 2, 5. Address of Listing Company: D-37079 Göttingen. Germany The examination and test results are recorded in confidential report number: 6. 3059596 dated 22<sup>nd</sup> May 2018 7. FM Approvals LLC, certifies that the equipment described has been found to comply with the following Approval standards and other documents: CSA C22.2 No. 25: 2017. CSA C22.2 No. 30: 1986 (R2016), CSA C22.2 No. 94.1: 2015. CSA C22.2 No. 94.2: 2015, CSA C22.2 No. 213: 2017, CAN/CSA-C22.2 No. 60079-0: 2015, CAN/CSA-C22.2 No. 60079-1: 2016, CAN/CSA-C22.2 No. 60079-7: 2016, CAN/CSA-C22.2 No. 60079-11: 2014, CAN/CSA-C22.2 No. 60079-18: 2016, CAN/CSA-C22.2 No. 60079-31: 2015, CAN/CSA C22.2 No. 60529: 2016, CAN/CSA C22.2 No. 61010-1: 2004, and ANSI/ISA 12.27.01: 2011 If the sign 'X' is placed after the certificate number, it indicates that the equipment is subject to specific 8. conditions of use specified in the schedule to this certificate. This certificate relates to the design, examination and testing of the products specified herein. The FM 9. Approvals surveillance audit program has further determined that the manufacturing processes and quality control procedures in place are satisfactory to manufacture the product as examined, tested and Approved. Certificate issued by: 9 Marguerch 24 August 2018 J/E. Marguedant Date VP, Manager, Electrical Systems To verify the availability of the Approved product, please refer to www.approvalguide.com

## THIS CERTIFICATE MAY ONLY BE REPRODUCED IN ITS ENTIRETY AND WITHOUT CHANGE





#### 10. Equipment Ratings:

#### FE\*631F1D (6 and 8) - Integral transmitter & sensor

Explosionproof for Class I, Division 1, Groups B, C and D T6...T1; Dust-ignitionproof for Class II, Division 1, Groups E, F and G, T6...T3B; Class III, Division 1, T6...T3B, Flameproof/increased safety/encapsulated with intrinsically safe outputs for Class I, Zone 1, Ex db eb mb [ia Ga] IIB+H2 T6...T1 Gb, protection by enclosure with intrinsically safe outputs for Zone 21 Ex tb [ia Da] IIIC T80°C...T165°C Db, hazardous locations, indoors and outdoors (Type 4X, IP65/67) with an ambient temperature rating of -40°C to +60°C.

#### FE\*632F1A (1 and 2) – Remote sensor

#### FE\*632F1U (1 and 2) - Remote sensor

Explosionproof for Class I, Division 1, Groups B, C and D T6...T1; Dust-ignitionproof for Class II, Division 1, Groups E, F and G, T6...T3B; Class III, Division 1, T6...T3B, Flameproof/increased safety/encapsulated for Class I, Zone 1, Ex db eb mb IIB+H2 T6...T1 Gb, protection by enclosure/intrinsic safety for Zone 21 Ex tb IIIC T80°C...T165°C Db hazardous locations, indoors and outdoors (Type 4X, IP65/67) with an ambient temperature rating of -40°C to +60°C.

#### FET632F1W (5 and 7) – Transmitter only

Explosionproof for Class I, Division 1, Groups B, C and D; Dust-ignitionproof for Class II, Division 1, Groups E, F and G, T6; Class III, Division 1, T6; Flameproof/increased safety/encapsulated with intrinsically safe outputs for Class I, Zone 1, Ex db [ia Ga] IIB + H<sub>2</sub> T6 Gb, protection by enclosure for Zone 21 Ex tb [ia Da] IIIC T80°C Db hazardous locations, indoors and outdoors (Type 4X, IP65/67 – IP68 Sensor only) with an ambient temperature rating of -40°C to +60°C.

#### FE\*632F2 – Integral transmitter & sensor

#### FEP632F2 – Remote sensor

#### FEH632F2 – Remote sensor

Nonincendive for Class I Division 2, Groups A, B, C and D T6...T1; Nonincendive for Class II, Division 2, Groups E, F and G, T6...T3B, Class III, Division 1, T6...T3B, Increased safety for Class I, Zone 2 Ex ec IIC T6...T1 Gc, protection by enclosure for Zone 21 Ex tb IIIC T80°C...T165°C Db hazardous locations, indoors and outdoors (Type 4X, IP65/67/68 – Sensor only) with an ambient temperature rating of -40°C to +60°C.

#### FET632F2– Remote transmitter

Nonincendive for Class I Division 2, Groups A, B, C and D, T6; Nonincendive for Class II, Division 2, Groups E, F and G, Class III, Division 1, Increased safety for Class I, Zone 2 Ex ec IIC T6 Gc, protection by enclosure for Zone 21 Ex tb IIIC T80°C Db hazardous locations, indoors and outdoors (Type 4X, IP65/67) with an ambient temperature rating of -40°C to +60°C.

11. The marking of the equipment shall include:

#### FE\*631F1D (6 and 8)

Class I Division 1, Groups B, C, D; T6...T1 Ta = -40°C to +60°C; Type 4X, IP65/67

#### THIS CERTIFICATE MAY ONLY BE REPRODUCED IN ITS ENTIRETY AND WITHOUT CHANGE

# **SCHEDULE**



Canadian Certificate Of Conformity No: FM17CA0033X

Class II, Division 1, Groups E, F, G, Class III, Division 1; T6...T3B Ta = -40°C to +60°C; Type 4X, IP65/67 Class I, Zone 1, Ex db eb mb [ia Ga] IIB+H2 T6...T1 Gb Ta = -40°C to +60°C; Type 4X, IP65/67 Zone 21, Ex tb [ia Da] IIIC T80°C...T165°C Db

## FE\*632F1A (1 and 2) FE\*632F1U (1 and 2)

Class I Division 1, Groups B, C, D; T6...T1 Ta = -40°C to +60°C; Type 4X, IP65/67 Type 4X, IP65/67/68 Class II, Division 1, Groups E, F, G, Class III, Division 1; T6...T3B Ta = -40°C to +60°C; Type 4X, IP65/67/68 Zone 1, Ex db eb mb IIB+H2 T6...T1 Gb Ta = -40°C to +60°C; Type 4X, IP65/67/68 Zone 21, Ex tb IIIC T80°C...T165°C Db

## FET632F1W (1 to 5 and 7)

Class I Division 1, Groups B, C, D; T6 Ta =  $-40^{\circ}$ C to  $+60^{\circ}$ C; Type 4X, IP65/67 Class II, Division 1, Groups E, F, G, Class III, Division 1; T6 Ta =  $-40^{\circ}$ C to  $+60^{\circ}$ C; Type 4X, IP65/67 Zone 1, Ex db [ia Ga] IIB + H<sub>2</sub> T6 Gb Ta =  $-40^{\circ}$ C to  $+60^{\circ}$ C; Type 4X, IP65/67 Zone 21, Ex tb [ia Da] IIIC T80°C Db

#### FE\*631F2

#### FEP632F2

## FEH632F2

Class I Division 2, Groups A, B, C, D; T6...T1 Ta = -40°C to +60°C; Type 4X, IP65/67/68 (sensor only) Class II, Division 2, Groups E, F, G, Class III, Division 1; T6...T3B Ta = -40°C to +60°C; Type 4X, IP65/67/68 (sensor only)

Zone 2, Ex ec IIC T6...T1 Gc Ta = -40°C to +60°C; Type 4X, IP65/67/68 (sensor only) Zone 21, Ex tb IIIC T80°C...T165°C Db

## FET632F2

Class I Division 2, Groups A, B, C, D; T6 Ta = -40°C to +60°C; Type 4X, IP65/67 Class II, Division 2, Groups E, F, G, Class III, Division 1; T6 Ta = -40°C to +60°C; Type 4X, IP65/67 Zone 2, Ex ec IIC T6 Gc Ta = -40°C to +60°C; Type 4X, IP65/67 Zone 21, Ex tb IIIC T80°C Db

#### 12. Description of Equipment:

## THIS CERTIFICATE MAY ONLY BE REPRODUCED IN ITS ENTIRETY AND WITHOUT CHANGE





**General** - The FEP6\_ \_ ProcessMaster, and FEH6\_ \_ HygienicMaster are series of electromagnetic flowmeters. The electronics enclosure is a cylindrical enclosure identified as a dual compartment Type 3 or a single compartment a rectangular housing identified as a Type 4. The ambient temperature range for the transmitters and sensors is either -20°C to +60°C or -40°C to +60°C depending on the options chosen.

The FEP6\_ \_ ProcessMaster, and FEH6\_ \_ HygienicMaster are both available as integral and remote designs. A high process temperature version is available and uses 40mm or 100mm stand-offs between the Primary and the electronics or remote connection facilities.

The sensor is available in two different versions: Process Sensor and Hygienic Sensor. The Process Sensor is available in meter size DN3 to DN2000, the Hygienic Sensor is available in meter size DN3 to DN100. The medium temperature range for the Hygienic Sensor and the medium temperature range for the Process Sensor identified as Design Level A are -40 °C to 130 °C for the normal temperature version and -40 °C to +180 °C for the high temperature version. The medium temperature range for sensors identified as Design Level B is -40 °C to 100 °C.

Enclosure rating IP65, IP67, or IP68 depending on the option selected.

#### Operation Temperature Ranges:

The ambient operating temperature range of the FE\*6 is -40°C to 60°C. Process temperature range is -40°C to 180°C. See ABB Instruction manual for details on the relationship between ambient temperature, process temperature and temperature class.

Electrical data: The FE\*6 has the following supply parameters;

Power Supply (Terminals L and N)  $U_{DC} = 16.8 \text{ to } 30 \text{ V}$  $U_{AC} = 100 \text{ V} (-15\%) \text{ to } 240 \text{ V} (+10\%)$ 

Power supply (=  $U_{LOW}$ );  $P_{MAX} = \le 20$  W; C, Ripple < 5 % Power supply (=  $U_{HIGH}$ ); S  $\le 20$  W


See ABB Drawing Number 3KXF000061G0009 for the parameters for the Current Output, Digital Output, and Digital Input connections.

#### FEH631F2fghijklmnopqrA-t.u.v – Hygienic Integral


NI/ I / 2 / ABCD / T6...T1 Ta = +60°C; Type 4X, IP65/67 NI / II / 2 / EFG / T6...T3B Ta = +60°C; Type 4X, IP65/67 DIP / III / 1 / T6...T3B Ta = +60°C; Type 4X, IP65/67 2 / Ex ec / IIC / T6...T1 Gc Ta = +60°C; Type 4X, IP65/67 21 / Ex tb / IIIC / T80°C...T165°C Db Ta = +60°C; Type 4X, IP65/67 Single Seal

- f = Housing Type/Housing Material/ Cable entry: S1, S2, D1, D2, D3, D4, D6, or D8
- g = Meter Size: 4-digit code not relevant for safety
- h = Process Connection Type: 2-digit code not relevant for safety
- i = Liner material: T1 or P1
- j = Process connection material: Single digit not relevant for safety
- k = Electrode design: 1, or 5
- I = Measuring electrode material: Single digit code not relevant for safety
- m = Grounding electrode/Full pipe detection: 0 or 2
- n = Grounding accessories: A, B or C


#### THIS CERTIFICATE MAY ONLY BE REPRODUCED IN ITS ENTIRETY AND WITHOUT CHANGE




#### THIS CERTIFICATE MAY ONLY BE REPRODUCED IN ITS ENTIRETY AND WITHOUT CHANGE



FM Approvals LLC. 1151 Boston-Providence Turnpike, Norwood, MA 02062 USA T: +1 (1) 781 762 4300 F: +1 (1) 781 762 9375 E-mail: <u>information@fmapprovals.com</u> <u>www.fmapprovals.com</u>









- n = Grounding accessories: A, B, C, D or E
- o = Protection class transmitter/protection class sensor: 70 or 91
- p = Power supply: A, D, C, or E
- q = Display: 1 or 2
- r = Outputs: G0, G1, G2, G3, Y0

Additional Codes

- t = Option card 1: DR0, DRN, DRG, DRT or DRA
- u = Option card 2:DR0, DSA, DSN, or DSG
- v = Temperature range of installation/Ambient temperature range: TK1, TK4, TKH or TKK
- w = Sensor housing material: SMA or SMS

## FEH632F1fghijklmnop8Y0A-t.u.v – Hygienic remote sensor

XP-IPA / I / 1 / BCD / T6...T1 Ta = +60°C; Type 4X, IP65/67/68 DIP / II / 1 / EFG / T6...T3B Ta = -40°C to +60°C; Type 4X, IP65/67/68 III / 1 / T6...T3B Ta = +60°C; Type 4X, IP65/67/68 1 / Ex db eb mb / IIB+H2 / T6...T1 Gb Ta = +60°C; Type 4X, IP65/67/68 21 / Ex tb / IIIC / T80°C...T165°C Db, Type 4X, IP65/67/68 Single Seal

- f = Housing Type/Housing Material/ Cable entry: A1, A2, U1, or U2
- g = Meter Size: 4-digit code not relevant for safety
- h = Process Connection Type: 2-digit code not relevant for safety
- i = Liner material: T1 or P1
- j = Process connection material: Single digit not relevant for safety
- k = Electrode design: 1, or 5
- I = Measuring electrode material: Single digit code not relevant for safety
- m = Grounding electrode/Full pipe detection: 0 or 2
- n = Grounding accessories: A, B or C
- o = Protection class transmitter/protection class sensor: 70, 76, 77 or 91
- p = Power supply: Y or W

#### Additional Codes

- t = Option card 1: DR0
- u = Option card 2: DR0
- v = Temperature range of installation/Ambient temperature range: TK1, TK4, TKH or TKK

#### FEP632F1fghijklmnop8Y0A-t.u.v.w – Process remote sensor

XP-IPA / I / I / BCD / T6...T1 Ta = +60°C; Type 4X, IP65/67/68 DIP / II / 1 / EFG / T6...T3B Ta = -40°C to +60°C; Type 4X, IP65/67/68 III / 1 / T6...T3B Ta = +60°C; Type 4X, IP65/67/68 1 / Ex db eb mb / IIB+H2 / T6...T1 Gb Ta = +60°C; Type 4X, IP65/67/68 21 / Ex tb / IIIC / T80°C...T165°C Db, Type 4X, IP65/67/68 Single Seal

- f = Housing Type/Housing Material/ Cable entry: A1, A2, U1, or U2
- g = Meter Size: 4-digit code not relevant for safety
- h = Process Connection Type: 2-digit code not relevant for safety
- i = Liner material: R2, R3, R4, E1, T1, T3, T2, P1, C1, E2 or P2
- j = Process connection material: Single digit not relevant for safety

#### THIS CERTIFICATE MAY ONLY BE REPRODUCED IN ITS ENTIRETY AND WITHOUT CHANGE





- k = Electrode design: 1, or 5
- I = Measuring electrode material: Single digit code not relevant for safety
- m = Grounding electrode/Full pipe detection: 0, 1, 2 or 3
- n = Grounding accessories: A, B, C, D or E
- o = Protection class transmitter/protection class sensor: 70, 76, 77 or 91
- p = Power supply: Y or W

Additional Codes

- t = Option card 1: DR0
- u = Option card 2: DR0
- v = Temperature range of installation/Ambient temperature range: TK1, TK4, TKH or TKK
- w = Sensor housing material: SMA or SMS

## FET632F1fopqr - t.u.v – Remote transmitter

XP-IS / I / 1 / BCD / T6 Ta = +60°C; Type 4X, IP65/67 DIP / II / 1 / EFG / T6 Ta = +60°C; Type 4X, IP65/67 III / 1 / T6 Ta = +60°C; Type 4X, IP65/67

1 / Ex db [ia Ga] / IIB + H2 / T6 Gb Ta = +60°C; Type 4X, IP65/67

- 21 / Ex tb [ia Da] / IIIC / T80°C Db Ta = +60°C; Type 4X, IP65/67
- f = Housing Type/Housing Material/ Cable entry: W1, W2, W3, W4, W5 or W7
- o = Protection class transmitter/protection class sensor: 70 or 91
- p = Power supply: A, D, C or E
- q = Display: 1 or 2
- r = Outputs: G0, G1, G2, G3 or Y0

Additional Codes

- t = Option card 1: DR0, DRN, DRG, DRT or DRA
- u = Option card 2: DR0, DSA, DSN or DSG
- v = Temperature range of installation/Ambient temperature range: TK1, TK4, TKH or TKK

#### 13. Schedule of Limitations:

1. The ABB Instruction Manual for the ProcessMaster and HygenicMaster details the permitted Temperature Classification and Ambient Temperature ratings as influenced by the Process Medium temperature.

2. The painted surface of the ProcessMaster and HygenicMaster may store electrostatic charge and become a source of ignition in applications with a low relative humidity <~30% relative humidity where the painted surface is relatively free of surface contamination such as dirt, dust, or oil. Guidance on protection against the risk of ignition due to electrostatic discharge can be found in IEC TR60079-32-2 Cleaning of the painted surface should only be done with a damp cloth.

3. Contact the manufacturer for specific flamepath joint details during repair of flameproof Ex d apparatus.

4. For Integral and Remote versions FE\*63\*F1 Zone 21 having exposed electrodes in the process shall be used in a non-flammable liquid process only.

5. For installations in flammable dust, the cable entries shall be fitted with an appropriate cable entry device meeting the requirements of IP6x fitted with a gasket or seal between the cable entry device and the wall of the enclosure.

#### THIS CERTIFICATE MAY ONLY BE REPRODUCED IN ITS ENTIRETY AND WITHOUT CHANGE





## 14. Test and Assessment Procedure and Conditions:

This Certificate has been issued in accordance with FM Approvals Canadian Certification Scheme.

#### 15. Schedule Drawings

Schedule Drawings A copy of the technical documentation has been kept by FM Approvals.

#### 16. Certificate History

Details of the supplements to this certificate are described below:

Date	Description					
22 <sup>nd</sup> May 2018	Original Issue.					
6 <sup>th</sup> July 2018	Supplement 1: Report Reference: RR214851 dated 6 <sup>th</sup> July 2018. Description of the Change: Editorial corrections to the certificate.					
24 <sup>th</sup> August 2018	Supplement 2: Report Reference: RR215360 dated 24 <sup>th</sup> August 2018. Description of the Change: Corrections to the certificate.					

# **MApprovals**

THIS CERTIFICATE MAY ONLY BE REPRODUCED IN ITS ENTIRETY AND WITHOUT CHANGE

## FM Approvals **CERTIFICATE OF CONFORMITY** Member of the FM Global Group 1. HAZARDOUS LOCATION ELECTRICAL PER CANADIAN REQUIREMENTS 2. **Certificate No:** FM17CA0033X 3. Equipment: FEP63 \_ ProcessMaster, and (Type Reference and Name) FEH63\_ HygienicMaster Electromagnetic Flowmeters, and FET63\_Transmitters Name of Listing Company: ABB Automation Products GmbH 4. Dransfelder Straße 2, Address of Listing Company: 5. D-37079 Göttingen, Germany The examination and test results are recorded in confidential report number: 6. 3059596 dated 22<sup>nd</sup> May 2018 7. FM Approvals LLC, certifies that the equipment described has been found to comply with the following Approval standards and other documents: CSA C22.2 No. 25: 2017, CSA C22.2 No. 30: 1986 (R2016), CSA C22.2 No. 94.1: 2015, CSA C22.2 No. 94.2: 2015, CSA C22.2 No. 213: 2017, CAN/CSA-C22.2 No. 60079-0: 2015, CAN/CSA-C22.2 No. 60079-1: 2016, CAN/CSA-C22.2 No. 60079-7: 2016, CAN/CSA-C22.2 No. 60079-11: 2014, CAN/CSA-C22.2 No. 60079-18: 2016, CAN/CSA-C22.2 No. 60079-31: 2015, CAN/CSA C22.2 No. 60529: 2016, CAN/CSA C22.2 No. 61010-1: 2004, and ANSI/ISA 12.27.01: 2011 If the sign 'X' is placed after the certificate number, it indicates that the equipment is subject to specific 8. conditions of use specified in the schedule to this certificate. 9. This certificate relates to the design, examination and testing of the products specified herein. The FM Approvals surveillance audit program has further determined that the manufacturing processes and quality control procedures in place are satisfactory to manufacture the product as examined, tested and Approved. Certificate issued by: Margueral 2 January 2019 J/E. Marguedant Date VP, Manager, Electrical Systems To verify the availability of the Approved product, please refer to www.approvalguide.com

THIS CERTIFICATE MAY ONLY BE REPRODUCED IN ITS ENTIRETY AND WITHOUT CHANGE

FM Approvals LLC. 1151 Boston-Providence Turnpike, Norwood, MA 02062 USA T: +1 (1) 781 762 4300 F: +1 (1) 781 762 9375 E-mail: <u>information@fmapprovals.com</u> <u>www.fmapprovals.com</u>





#### 10. Equipment Ratings:

#### FE\*631F1D (6 and 8) - Integral transmitter & sensor

Explosionproof for Class I, Division 1, Groups B, C and D T6...T1; Dust-ignitionproof for Class II, Division 1, Groups E, F and G, T6...T3B; Class III, Division 1, T6...T3B, Flameproof/increased safety/encapsulated with intrinsically safe outputs for Class I, Zone 1, Ex db eb mb [ia Ga] IIB+H2 T6...T1 Gb, protection by enclosure with intrinsically safe outputs for Zone 21 Ex tb [ia Da] IIIC T80°C...T165°C Db, hazardous locations, indoors and outdoors (Type 4X, IP65/67) with an ambient temperature rating of -40°C to +60°C.

#### FE\*632F1A (1 and 2) – Remote sensor

#### FE\*632F1U (1 and 2) - Remote sensor

Explosionproof for Class I, Division 1, Groups B, C and D T6...T1; Dust-ignitionproof for Class II, Division 1, Groups E, F and G, T6...T3B; Class III, Division 1, T6...T3B, Flameproof/increased safety/encapsulated for Class I, Zone 1, Ex db eb mb IIB+H2 T6...T1 Gb, protection by enclosure/intrinsic safety for Zone 21 Ex tb IIIC T80°C...T165°C Db hazardous locations, indoors and outdoors (Type 4X, IP65/67) with an ambient temperature rating of -40°C to +60°C.

#### FET632F1W (5 and 7) - Transmitter only

Explosionproof for Class I, Division 1, Groups B, C and D; Dust-ignitionproof for Class II, Division 1, Groups E, F and G, T6; Class III, Division 1, T6; Flameproof/increased safety/encapsulated with intrinsically safe outputs for Class I, Zone 1, Ex db [ia Ga] IIB + H<sub>2</sub> T6 Gb, protection by enclosure for Zone 21 Ex tb [ia Da] IIIC T80°C Db hazardous locations, indoors and outdoors (Type 4X, IP65/67 – IP68 Sensor only) with an ambient temperature rating of -40°C to +60°C.

#### FE\*632F2 – Integral transmitter & sensor

#### FEP632F2 – Remote sensor

#### FEH632F2 – Remote sensor

Nonincendive for Class I Division 2, Groups A, B, C and D T6...T1; Nonincendive for Class II, Division 2, Groups E, F and G, T6...T3B, Class III, Division 1, T6...T3B, Increased safety for Class I, Zone 2 Ex ec IIC T6...T1 Gc, protection by enclosure for Zone 21 Ex tb IIIC T80°C...T165°C Db hazardous locations, indoors and outdoors (Type 4X, IP65/67/68 – Sensor only) with an ambient temperature rating of -40°C to +60°C.

#### FET632F2– Remote transmitter

Nonincendive for Class I Division 2, Groups A, B, C and D, T6; Nonincendive for Class II, Division 2, Groups E, F and G, Class III, Division 1, Increased safety for Class I, Zone 2 Ex ec IIC T6 Gc, protection by enclosure for Zone 21 Ex tb IIIC T80°C Db hazardous locations, indoors and outdoors (Type 4X, IP65/67) with an ambient temperature rating of -40°C to +60°C.

11. The marking of the equipment shall include:

#### FE\*631F1D (6 and 8)

Class I Division 1, Groups B, C, D; T6...T1 Ta = -40°C to +60°C; Type 4X, IP65/67

#### THIS CERTIFICATE MAY ONLY BE REPRODUCED IN ITS ENTIRETY AND WITHOUT CHANGE

# **SCHEDULE**



## Canadian Certificate Of Conformity No: FM17CA0033X

Class II, Division 1, Groups E, F, G, Class III, Division 1; T6...T3B Ta = -40°C to +60°C; Type 4X, IP65/67 Class I, Zone 1, Ex db eb mb [ia Ga] IIB+H2 T6...T1 Gb Ta = -40°C to +60°C; Type 4X, IP65/67 Zone 21, Ex tb [ia Da] IIIC T80°C...T165°C Db

## FE\*632F1A (1 and 2) FE\*632F1U (1 and 2)

Class I Division 1, Groups B, C, D; T6...T1 Ta = -40°C to +60°C; Type 4X, IP65/67 Type 4X, IP65/67/68 Class II, Division 1, Groups E, F, G, Class III, Division 1; T6...T3B Ta = -40°C to +60°C; Type 4X, IP65/67/68 Zone 1, Ex db eb mb IIB+H2 T6...T1 Gb Ta = -40°C to +60°C; Type 4X, IP65/67/68 Zone 21, Ex tb IIIC T80°C...T165°C Db

## FET632F1W (1 to 5 and 7)

Class I Division 1, Groups B, C, D; T6 Ta =  $-40^{\circ}$ C to  $+60^{\circ}$ C; Type 4X, IP65/67 Class II, Division 1, Groups E, F, G, Class III, Division 1; T6 Ta =  $-40^{\circ}$ C to  $+60^{\circ}$ C; Type 4X, IP65/67 Zone 1, Ex db [ia Ga] IIB + H<sub>2</sub> T6 Gb Ta =  $-40^{\circ}$ C to  $+60^{\circ}$ C; Type 4X, IP65/67 Zone 21, Ex tb [ia Da] IIIC T80°C Db

#### FE\*631F2

## FEP632F2

#### FEH632F2

Class I Division 2, Groups A, B, C, D; T6...T1 Ta = -40°C to +60°C; Type 4X, IP65/67/68 (sensor only) Class II, Division 2, Groups E, F, G, Class III, Division 1; T6...T3B Ta = -40°C to +60°C; Type 4X, IP65/67/68 (sensor only)

Zone 2, Ex ec IIC T6...T1 Gc Ta = -40°C to +60°C; Type 4X, IP65/67/68 (sensor only) Zone 21, Ex tb IIIC T80°C...T165°C Db

#### **FET632F2**

Class I Division 2, Groups A, B, C, D; T6 Ta = -40°C to +60°C; Type 4X, IP65/67 Class II, Division 2, Groups E, F, G, Class III, Division 1; T6 Ta = -40°C to +60°C; Type 4X, IP65/67 Zone 2, Ex ec IIC T6 Gc Ta = -40°C to +60°C; Type 4X, IP65/67 Zone 21, Ex tb IIIC T80°C Db

#### 12. Description of Equipment:

#### THIS CERTIFICATE MAY ONLY BE REPRODUCED IN ITS ENTIRETY AND WITHOUT CHANGE





**General** - The FEP6\_ \_ ProcessMaster, and FEH6\_ \_ HygienicMaster are series of electromagnetic flowmeters. The electronics enclosure is a cylindrical enclosure identified as a dual compartment Type 3 or a single compartment a rectangular housing identified as a Type 4. The ambient temperature range for the transmitters and sensors is either -20°C to +60°C or -40°C to +60°C depending on the options chosen.

The FEP6\_ \_ ProcessMaster, and FEH6\_ \_ HygienicMaster are both available as integral and remote designs. A high process temperature version is available and uses 40mm or 100mm stand-offs between the Primary and the electronics or remote connection facilities.

The sensor is available in two different versions: Process Sensor and Hygienic Sensor. The Process Sensor is available in meter size DN3 to DN2000, the Hygienic Sensor is available in meter size DN3 to DN100. The medium temperature range for the Hygienic Sensor and the medium temperature range for the Process Sensor identified as Design Level A are -40 °C to 130 °C for the normal temperature version and -40 °C to +180 °C for the high temperature version. The medium temperature range for sensors identified as Design Level B is -40 °C to 100 °C.

Enclosure rating IP65, IP67, or IP68 depending on the option selected.

#### Operation Temperature Ranges:

The ambient operating temperature range of the FE\*6 is -40°C to 60°C. Process temperature range is -40°C to 180°C. See ABB Instruction manual for details on the relationship between ambient temperature, process temperature and temperature class.

Electrical data: The FE\*6 has the following supply parameters;

Power Supply (Terminals L and N)  $U_{DC} = 16.8 \text{ to } 30 \text{ V}$  $U_{AC} = 100 \text{ V} (-15\%) \text{ to } 240 \text{ V} (+10\%)$ 

Power supply (=  $U_{LOW}$ );  $P_{MAX} = \le 20$  W; C, Ripple < 5 % Power supply (=  $U_{HIGH}$ ); S  $\le 20$  W


See ABB Drawing Number 3KXF000061G0009 for the parameters for the Current Output, Digital Output, and Digital Input connections.

#### FEH631F2fghijklmnopqrA-t.u.v – Hygienic Integral


NI/ I / 2 / ABCD / T6...T1 Ta = +60°C; Type 4X, IP65/67 NI / II / 2 / EFG / T6...T3B Ta = +60°C; Type 4X, IP65/67 DIP / III / 1 / T6...T3B Ta = +60°C; Type 4X, IP65/67 2 / Ex ec / IIC / T6...T1 Gc Ta = +60°C; Type 4X, IP65/67 21 / Ex tb / IIIC / T80°C...T165°C Db Ta = +60°C; Type 4X, IP65/67 Single Seal

- f = Housing Type/Housing Material/ Cable entry: S1, S2, D1, D2, D3, D4, D6, or D8
- g = Meter Size: 4-digit code not relevant for safety
- h = Process Connection Type: 2-digit code not relevant for safety
- i = Liner material: T1 or P1
- j = Process connection material: Single digit not relevant for safety
- k = Electrode design: 1, or 5
- I = Measuring electrode material: Single digit code not relevant for safety
- m = Grounding electrode/Full pipe detection: 0 or 2
- n = Grounding accessories: A, B or C


#### THIS CERTIFICATE MAY ONLY BE REPRODUCED IN ITS ENTIRETY AND WITHOUT CHANGE




T: +1 (1) 781 762 4300 F: +1 (1) 781 762 9375 E-mail: information@fmapprovals.com www.fmapprovals.com



T: +1 (1) 781 762 4300 F: +1 (1) 781 762 9375 E-mail: information@fmapprovals.com www.fmapprovals.com





# **SCHEDULE**



## Canadian Certificate Of Conformity No: FM17CA0033X

- n = Grounding accessories: A, B, C, D or E
- o = Protection class transmitter/protection class sensor: 70 or 91
- p = Power supply: A, D, C, or E
- q = Display: 1 or 2
- r = Outputs: G0, G1, G2, G3, G4, G5, G6, G7, G8, G9, M5, D1 or Y0

Additional Codes

- t = Option card 1: DR0, DRN, DRG, DRT or DRA
- u = Option card 2:DR0, DSA, DSN, DRM, DRD or DSG
- v = Temperature range of installation/Ambient temperature range: TK1, TK4, TKH or TKK
- w = Sensor housing material: SMA or SMS

## FEH632F1fghijklmnop8Y0A-t.u.v – Hygienic remote sensor

XP-IPA / I / 1 / BCD / T6...T1 Ta = +60°C; Type 4X, IP65/67/68 DIP / II / 1 / EFG / T6...T3B Ta = -40°C to +60°C; Type 4X, IP65/67/68 III / 1 / T6...T3B Ta = +60°C; Type 4X, IP65/67/68 1 / Ex db eb mb / IIB+H2 / T6...T1 Gb Ta = +60°C; Type 4X, IP65/67/68 21 / Ex tb / IIIC / T80°C...T165°C Db, Type 4X, IP65/67/68 Single Seal

- f = Housing Type/Housing Material/ Cable entry: A1, A2, U1, or U2
- g = Meter Size: 4-digit code not relevant for safety
- h = Process Connection Type: 2-digit code not relevant for safety
- i = Liner material: T1 or P1
- j = Process connection material: Single digit not relevant for safety
- k = Electrode design: 1, or 5
- I = Measuring electrode material: Single digit code not relevant for safety
- m = Grounding electrode/Full pipe detection: 0 or 2
- n = Grounding accessories: A, B or C
- o = Protection class transmitter/protection class sensor: 70, 76, 77 or 91
- p = Power supply: Y or W

#### Additional Codes

- t = Option card 1: DR0
- u = Option card 2: DR0
- v = Temperature range of installation/Ambient temperature range: TK1, TK4, TKH or TKK

#### FEP632F1fghijklmnop8Y0A-t.u.v.w – Process remote sensor

XP-IPA / I / 1 / BCD / T6...T1 Ta = +60°C; Type 4X, IP65/67/68 DIP / II / 1 / EFG / T6...T3B Ta = -40°C to +60°C; Type 4X, IP65/67/68 III / 1 / T6...T3B Ta = +60°C; Type 4X, IP65/67/68 1 / Ex db eb mb / IIB+H2 / T6...T1 Gb Ta = +60°C; Type 4X, IP65/67/68 21 / Ex tb / IIIC / T80°C...T165°C Db, Type 4X, IP65/67/68 Single Seal

- f = Housing Type/Housing Material/ Cable entry: A1, A2, U1, or U2
- g = Meter Size: 4-digit code not relevant for safety
- h = Process Connection Type: 2-digit code not relevant for safety
- i = Liner material: R2, R3, R4, E1, T1, T3, T2, P1, C1, E2 or P2
- j = Process connection material: Single digit not relevant for safety

#### THIS CERTIFICATE MAY ONLY BE REPRODUCED IN ITS ENTIRETY AND WITHOUT CHANGE





- k = Electrode design: 1, or 5
- I = Measuring electrode material: Single digit code not relevant for safety
- m = Grounding electrode/Full pipe detection: 0, 1, 2 or 3
- n = Grounding accessories: A, B, C, D or E
- o = Protection class transmitter/protection class sensor: 70, 76, 77 or 91
- p = Power supply: Y or W

**Additional Codes** 

- t = Option card 1: DR0
- u = Option card 2: DR0
- v = Temperature range of installation/Ambient temperature range: TK1, TK4, TKH or TKK
- w = Sensor housing material: SMA or SMS

#### FET632F1fopqr - t.u.v - Remote transmitter

XP-IS / I / 1 / BCD / T6 Ta = +60°C; Type 4X, IP65/67

DIP / II / 1 / EFG / T6 Ta = +60°C; Type 4X, IP65/67

III / 1 / T6 Ta = +60°C; Type 4X, IP65/67

1 / Ex db [ia Ga] / IIB + H2 / T6 Gb Ta = +60°C; Type 4X, IP65/67

- 21 / Ex tb [ia Da] / IIIC / T80°C Db Ta = +60°C; Type 4X, IP65/67
- f = Housing Type/Housing Material/ Cable entry: W1, W2, W3, W4, W5 or W7
- o = Protection class transmitter/protection class sensor: 70 or 91
- p = Power supply: A, D, C or E
- q = Display: 1 or 2
- r = Outputs: G0, G1, G2, G3, G4, G5, G6, G7, G8, G9, M5, D1 or Y0

Additional Codes

- t = Option card 1: DR0, DRN, DRG, DRT or DRA
- u = Option card 2: DR0, DSA, DSN, DRM, DRD or DSG
- v = Temperature range of installation/Ambient temperature range: TK1, TK4, TKH or TKK

#### 13. Schedule of Limitations:

1. The ABB Instruction Manual for the ProcessMaster and HygenicMaster details the permitted Temperature Classification and Ambient Temperature ratings as influenced by the Process Medium temperature.

2. The painted surface of the ProcessMaster and HygenicMaster may store electrostatic charge and become a source of ignition in applications with a low relative humidity <~30% relative humidity where the painted surface is relatively free of surface contamination such as dirt, dust, or oil. Guidance on protection against the risk of ignition due to electrostatic discharge can be found in IEC TR60079-32-2 Cleaning of the painted surface should only be done with a damp cloth.

3. Contact the manufacturer for specific flamepath joint details during repair of flameproof Ex d apparatus.

4. For Integral and Remote versions FE\*63\*F1 Zone 21 having exposed electrodes in the process shall be used in a non-flammable liquid process only.

5. For installations in flammable dust, the cable entries shall be fitted with an appropriate cable entry device meeting the requirements of IP6x fitted with a gasket or seal between the cable entry device and the wall of the enclosure.

#### THIS CERTIFICATE MAY ONLY BE REPRODUCED IN ITS ENTIRETY AND WITHOUT CHANGE





## 14. Test and Assessment Procedure and Conditions:

This Certificate has been issued in accordance with FM Approvals Canadian Certification Scheme.

#### 15. Schedule Drawings

A copy of the technical documentation has been kept by FM Approvals.

#### 16. Certificate History

Details of the supplements to this certificate are described below:

Date	Description				
22 <sup>nd</sup> May 2018	Original Issue.				
6 <sup>th</sup> July 2018	Supplement 1: Report Reference: RR214851 dated 6 <sup>th</sup> July 2018. Description of the Change: Editorial corrections to the certificate.				
24 <sup>th</sup> August 2018	Supplement 2: Report Reference: RR215360 dated 24 <sup>th</sup> August 2018. Description of the Change: Corrections to the certificate.				
2 <sup>nd</sup> January 2019	Supplement 3: Report Reference: RR215454 dated 2 <sup>nd</sup> January 2019. Description of the Change: Addition of Modbus option card. Modifications to PWBs.				

**VI Approvals** 

## THIS CERTIFICATE MAY ONLY BE REPRODUCED IN ITS ENTIRETY AND WITHOUT CHANGE